




Lakelands Concrete Products, Inc.  
7520 East Main St., Lima, NY 14485  
Phone: 585-624-1990, Fax: 585-624-2102

Web: [www.lakelandsconcrete.com](http://www.lakelandsconcrete.com)  
E-mail: [sales@lakelandsconcrete.com](mailto:sales@lakelandsconcrete.com)

Date: 2/2/01

DWG: LC3490

Leaching Chamber  
3490 Gal.






Lakelands Concrete Products, Inc.  
7520 East Main St., Lima, NY 14485  
Phone: 585-624-1990, Fax: 585-624-2102

Web: [www.lakelandsconcrete.com](http://www.lakelandsconcrete.com)  
E-mail: [sales@lakelandsconcrete.com](mailto:sales@lakelandsconcrete.com)

Date: 2/2/01

DWG: LC3490


Leaching Chamber  
3490 Gal.



PLAN VIEW

Specifications:  
Concrete: 5000psi @ 28 Days  
Entrained Air: 5% - 9%  
Design Load: AASHTO HS20  
Reinforcing: fy= 60,000psi ASTM A615

Notes:  
\*Cast Iron Frame And Grate/Covers Available  
\*Hole Size 1 5/8" x 3 1/8"



SECTION VIEW 'A'

Weight:  
Tank And Cover: 17,000#