

## SPECIFICATIONS

### SECTION 03420

#### PRECAST CONCRETE DUGOUTS

##### PART 1 – GENERAL

###### 1.1 DESCRIPTION

A. The work includes the supply and installation of precast concrete Dugouts, complete in- place, at the location, and in accordance with the contract drawings and as specified herein.

B. The manufacturer of the building shall be an organization specializing in the manufacture of precast concrete buildings for at least 5 years.

C. Producer shall be certified by the Prestressed Concrete Institute (PCI) Plant Certification Program. Manufacturer shall be certified at the time of bidding. Certification shall be in the following product group and categories: A1. (Architectural Precast Concrete)

###### 1.2 – SUBMITTAL

###### 1.2.1 SHOP DRAWINGS

A. Shop Drawings and Design Calculations shall be signed and sealed by a Professional Engineer registered in the State of New York.

B. Before starting fabrication, submit Shop Drawings showing layout, dimensions, anchorages, connections and connection accessories.

##### PART 2 – PRODUCTS

###### 2.1 PRECAST CONCRETE

A. The structural design for the Precast Concrete Dugouts shall be performed in accordance with the ANSI Building Code Requirements for minimum design loads in building and other structures:

1. Wind Load = 27 PSF
2. Snow Load = 60 PSF

B. Concrete shall have a 28 day strength of 6000 PSI. Building shall meet the ACI 318 Building Code requirements, or latest edition, for reinforced concrete.

C. Air entraining admixture, conforming to ASTM C260, shall be added to produce between 5 to 9 percent air by volume.

D. Reinforcing steel shall be in with the Concrete Reinforcing Institute Manual of standard practice. Reinforcing steel shall be in conformance with ASTM A615 grade 60 and welded wire fabric shall be ASTM A185.

E. Walls shall be a min 4 3/4” thick. Building shall be leak proof and corrosion proof with a 2 hour fire rating. Wall panels shall have a natural concrete, uniform interior broom finish. Exterior shall have an exposed aggregate finish with smooth concrete bands at the corners.

F. Roof thickness shall vary and slope away from the Dugout opening. Roof shall have a minimum 3” overhang on all sides, and a continuous, built in drip edge. Roof edge shall have a smooth form finish.

G. Panel-to-Panel, Panel-to-Roof and Panel-to-Floor connections shall be A36/A709-36 zinc plated steel, with a minimum dimension of 5"x5"x1/2". Washers shall be zinc plated A36 steel 3"x3"x1/4" with (1) 9/16" hole. Bolts shall be 1/2" diameter ASTM A449 Grade 5 with locking washer.

H. Panel-to-Roof and Panel-to-Floor gasket shall be 1" wide x 1/2" thick closed cell neoprene NYSDOT 705.08

J. Caulk all joints inside and out, caulk shall be BASF Sonolastic NP-1, color shall be Limestone.

2.2 INSULATION – Not Applicable

2.3 DOORS AND HARDWARE

A. Doors and Frames shall be 3'-0" x 7'-0" x 1 3/4" for single doors and 6'-0" x 7'-0" x 1 3/4" for double doors. Doors shall be The Fleming D-Series 18 Ga. Steel door. Frames shall be The Fleming F-16 Series, 16 Ga., 4" weld, punched and dimpled frame with 2" head.

B. Hinges shall be stainless steel with full mortise and concealed area. Hinges shall be Stanley CECB 1900-54 4"x4".

C. Threshold shall be National Guard Products, Saddle Threshold #613DKB.

D. Dead Bolt shall be Schlage B660Px626 heavy duty dead bolt with strike.

E. Closer shall be Norton 8501-AL closer tested and certified under ANSI Standard A156.4 grade one.

F. Push and Pull Plates shall be Burns 54 push plate and 26B pull plate.

G. Sweeps shall be National Guard Products, 601DKB sweeps.

2.4 PENETRATIONS: Penetrations shall be neat and any damage to surrounding surfaces shall be repaired. All penetrations shall be verified by the contractor prior to fabrication.

2.5 LOUVERS AND VENTS: Provide openings for louvers and vents as indicated on the drawings.

2.6 MANUFACTURERS: The precast building, complete with all accessories outlined above, shall be Lakelands Concrete Products Inc., or equal

### PART 3 – EXECUTION

A. The precast building shall be shipped to the jobsite and erected in place as shown on the contract drawings.

B. After all piping, wiring and utilities have been installed, tested and approved, contractor to clean the interior and exterior, and adjust doors to provide a weather tight seal.

### PART 4 – WARRANTY

A. Precast concrete manufacturer shall guarantee precast concrete products against defects in materials and workmanship for a period of 1 year after delivery and erection.

END OF SECTION