



Lakelands Concrete Products, Inc.
 7520 East Main St., Lima, NY 14485
 Phone: 585-624-1990, Fax: 585-624-2102

Web: www.lakelandsconcrete.com
 E-mail: sales@lakelandsconcrete.com

Date: 5/16/02

DWG: HOLD TNKS

HOLDING TANKS

SEE MANHOLES/VAULTS SECTION FOR DRAWINGS OF VAULTS WHICH CAN BE USED AS HOLDING TANKS. EACH VAULT IS CAPABLE OF WITHSTANDING LATERAL EARTH PRESSURE WHEN EMPTY. FOR LARGER CAPACITY TANKS, PLUMB TWO HOLDING TANKS TOGETHER. THESE VAULTS CAN BE USED AS SEPARATION TANKS WITH A BAFFLE WALL PLACED INSIDE THE VAULT. THE CONTRACTOR IS REQUIRED TO GROUT THE JOINTS TO ENSURE WATERTIGHTNESS.

FLOW LINE	5'-0"	5'-6"	6'-0"	6'-6"	7'-0"	7'-6"	8'-0"
VAULT	GAL.	GAL.	GAL.	GAL.	GAL.	GAL.	GAL.
HT46	898	988	1077	1167	1257		
HT479	1020	1122	1224	1326	1428	1530	1632
HT59	1575	1733	1890	2047	2205	2363	2520
HT66	1347	1481	1616	1751	1885	2020	2155
HT610	2025	2228	2430	2632	2835	3037	3240
HT612	2700	2970	3240	3510	3780	4050	4320
HT38Y	2700	2970	3240	3510	3780	4050	4320
HT714	3672	4039	4406	4774	5140	5508	5875
HT616	3420	3762	4104	4446	4788	5130	5472
HT719	4674	5141	5608	6076	6543	7011	7478

* NOTE: GT1050 CAN BE USED WITHOUT BAFFLE WALLS AS A 1200 GALLON HOLDING TANK

